Technical Report



Technical Report No.: 64.181.24.00497.01 Rev.00

Date: 2024-06-17

Client: Name: ThermoFLUX d.o.o

> Address: Bage 3, 70101 Jajce, Bosnia and Herzegovina

Contact person: Amel Kopić

Manufacturer: ThermoFLUX d.o.o Name:

> Address: Bage 3, 70101 Jajce, Bosnia and Herzegovina

Test object: Product: DC Inverter Air Source Heat Pumps

> Model: MONOBLOCK TF18 R290 CT 220V

Trade mark: ThermoFLUX

Test specification: EN 14825:2022 4

> EN 12102-1:2022 4 EN 14511-3:2022 **√**

EN 14511-4:2022 Clause 4 **4**

Purpose of Test according to the test specification

examination:

1 (EU) No 813/2013

4 EU 2016/2282:2016-11-30

Test result: The test results show that the presented product is in compliance with the above

listed test specifications.

Any use for advertising purposes must be granted in writing. This technical report may only be quoted in full. This report is the result of a single examination of the object in question. It does not imply a general statement regarding the quality of products from regular production. For further details please see Testing, Certification, Validation and Verification Regulations, chapter A-3.3.

www.tuvsud.com

Project No: 64.181.24.00497.01

Rev.: 00

Date: 2024-06-17 Page: 1 of 19

TÜV SÜD Certification and Testing (China) Co., Ltd.

Road, Huangpu Ave. West, Guangzhou 510656, China Tel: +86 20 38320668

Function

Rated Power (W):

Rated Current (A): Protection Class:

Supply connection:

Operation mode:

Construction:

Protection Against Moisture :

Description of the test object

1

1.1



	Mar	nufacturer's specification for in	tended use:					
	The appliance is air to water heat pump.							
	Mar	nufacturer's specification for pr	redictive use:					
	Acc	ording to user manual						
1.2	Coi	nsideration of the foresee	able use					
		Not applicable						
	7	Covered through the applied	standard					
		Covered by the following con	nment					
		Covered by attached risk and	alysis					
1.3	Tec	chnical Data						
	Mod	del :	MONOBLOCK TF18 R290 CT 220V					
	Rate	ed Voltage (V):	220-240V~					
	Rate	ed Frequency (Hz) :	50					

7830 37.50

Class I

IP X4

 \checkmark

 \checkmark

Stationary

Non detachable cord

Continuous operation;

Permanent connection to fixed wiring

Intermittent operation; Short time operation;

Refrigerant/charge (kg): R290 / 1.80kg

Declared parameters: Average Colder 7 Warmer

Sound power level dB(A): N/A

Series No: KAL092210600500116



Project No: 64.181.24.00497.01

Rev.: 00

Date: 2024-06-17 Page: 2 of 19



TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China Tel: +86 20 38320668





2 Order

2.1 **Date of Purchase Order, Customer's Reference**

Date of Purchase Order: 2023-08-31, 2024-06-17

Customer's Reference: ThermoFLUX d.o.o

2.2 Test Sample(s)

2023-08-31 • Reception date(s):

• Location(s) of reception:

For Energy test:

Guangzhou Customs District Technology Center

(CNAS accredited laboratory with Registration No.CNAS L2322)

Address: No.3, Desheng East Road, Daliang, Shunde District, Foshan, Guangdong, China

For Noise tests:

CVC Testing Technology Co., Ltd.

(CNAS accredited laboratory with Registration No.CNAS L0095)

Address: No.3, Tiantai Yilu, Kaitai Avenue, Science City, Guangzhou, Guangdong, China

completed and can be normal operation Condition of test sample(s):

Date(s) of Testing 2.3

2023-08-31 to 2023-10-30

2.4 Location(s) of Testing

Same as 2.2

Points of Non-compliance or Exceptions of the Test Procedure

N/A

3 **Test Results**

□ Decision	rule acco	rding	to ILA	AC-G8	3:09/20	19 clau	se 4.2.1 B	inaı	y state	ment f	or simple	Э
acceptance	rule or IE	C G	uide 1	15:202	23, clau	ıse 4.3	Simple ac	сер	tance v	was ap	plied.	

☐ Decision rule according to customer's requirements was applied. It is:

- ☐ Decision rule according to ILAC-G8:09/2019 clause 4.2.2 Binary statement with guard band guard band length = 95 % extended measurement uncertainty, was applied.
- ☐ Decision rule (based on ILAC-G8:09/2019 clause 4.2.3 Non-binary statement with guard band, guard band length = 95 % extended measurement uncertainty) for an upper specification limit (A lower limit or specification with an up-per and a lower limit is treated similarly.):
- Compliance with the requirement: If a specification limit is not breached by a measurement result plus the expanded uncertainty with a 95% coverage probability, then compliance with the specification will be stated (e. g. Pass).
- · Non-compliance with the requirement: If a specification limit is exceeded by the measurement result minus the expanded uncertainty with a 95% coverage probability, then non-compliance with the specification will be stated (e. g. Fail).
- Inconclusive result: If a measurement result plus/minus the expanded uncertainty with a 95 % coverage probability overlaps the limit it will be stated that it is not possible to state compliance or non-compliance.
- ☐ There are no statements to conformity or no results with measurand stated in this report, no decision rule has been applied.



Rev.: 00 Date: 2024-06-17 Page: 3 of 19



www.tuvsud.com



3.1 Positive Test Results

See Appendix I

4 Remarks

4.1 General

The user manual has been examined according to the minimum requirements described in the product standard. The manufacturer is responsible for the accuracy of further particulars as well as of the composition and layout.

4.2 When the product is placed on the market, it must be accompanied with safety Instructions written in official language of the country. The instructions shall give information regarding safe operation, installation and maintenance.

5 Documentation

• Appendix I: Test results

· Appendix II: Marking plate

· Appendix III: photo documentation

· Appendix IV: Construction data form

• Appendix V: Test equipment list

6 Test History

- 1) These appliances are Air To Water Heat Pump Unit, each one including a whole compression type refrigerant circuit to heat water in another circuit. These appliances were for cooling and heating water function, this report only for heating capacity test.
- 2) The main power is supplied by a 3-pole supply cord connecting to fixed wiring.
- 3) Water enthalpy method was adopted in this report.
- 4) Standby mode power, off mode power and thermostat-off mode power were tested according to clause 12 of standard EN 14825:2022.
- 5) This test report 64.181.24.00497.01 Rev.00, dated 2024-06-17 bases on original test report 64.181.23.03117.01 Rev.00, dated 2023-11-07 to include the following changes and/or additions, which were considered technical modifications:
 - a) Changing report holder name and address, manufacturer name and address, trademark and model name.
 - b) After evaluating, no additional test was needed.

TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch TÜV SÜD Group

Tested by: William Liang, Project Handler

printed name, function & signature

Approved by: Plum Li, Designated Reviewer

printed name, function & signature

Gu

Rev.: 00 Date: 2024-06-17 Page: 4 of 19

Project No: 64.181.24.00497.01






Table 1.	Heating mod	e (Low tem	peratu	re applica	ation):				P	
Model	MONOBLOC	K TF18 R290) CT 2	20V						
Product type	Air to Water	Heating season	7	Average		Warme	r 🗆	Colder		
1. Test condit	tions:									
Condition	F	Part Load Rain %	atio		hea	Outdoo at exchai			or heat anger	
Condition	Form	nula		verage imates		dry (wet perature			tlet water tures (°C)	
Α	(-7-16)/(Tdesignh-16)			88		-7(-8)		a /	' 34	
В	(+2-16)/ (Td	esignh-16)		54		2(1)		a /	' 30	
С	(+7-16)/(Td	esignh-16)		35		7(6)		a /	27	
D	(+12-16)/(To	lesignh-16)		15		12(11)		a /	′ 24	
E	(TOL	-16)/ (Tdesi	gnh-16	5)		TOL		a /	35.3	
F	(Tbival	signh-16)			Tbiv		a / 34			
G	(-15-16)/(Tdesignh-16)			N/A	-15			N	N/A	
2.Tested data		•		0.000	A 7 0 0 1 6) , ^	40000	1 4/40	L 4 / 7 / 74/0 /	
General test conditions/ Part-Load	Unit	A(-7)/W34 (88%)		2/W30 54%)	A7/W2 (35%		12/W24 (15%)	A(-10)/ W35.3 (100%)	A(-7)/W34 (88%)	
		А		В	С		D	Е	F	
Data collection period	hh: min:sec	3:00:00	1:	:10:00	1:10:0	0 1	:10:00	1:10:00	3:00:00	
The heat pump defrosts		Yes		No	No		No	No	Yes	
Electrical Prop	erties							-		
Voltage	V	229.7	2	229.6	230.8	3	230.9	229.1	229.7	
Current input of the unit	А	17.61		6.19	4.73		4.24	20.14	17.61	
Power input of the unit	kW	4.015	,	1.372	1.033	3	0.919	4.575	4.015	
Compressor frequency	Hz	85		35	30		30	85	85	

Doc No.: ITC-TTW0902.02E - Rev.15

Project No: 64.181.24.00497.01

Rev.: 00 Date: 2024-06-17 Page: 5 of 19







Test conditions	s User Side									
Water flow	m³/h	2.20	2.20	2.20	2.20	2.20	2.20			
Inlet Water temperature	°C	29.49	27.40	25.34	23.20	30.65	29.49			
Outlet Water temperature	°C	33.72*	29.99	28.12	26.35	35.21	33.72*			
Test conditions Source Side										
Barometric pressure	kPa	101.02	101.01	101.01	101.02	101.01	101.02			
Air inlet temperature, DB	°C	-6.95	2.02	7.00	12.00	-10.00	-6.95			
Air inlet temperature, WB	°C	-7.87	1.00	6.01	10.99	-11.08	-7.87			
Summary of th	e results									
Total heating capacity	kW	10.765	6.594	7.070	8.021	11.560	10.765			
Effective power input	kW	3.999	1.355	1.017	0.903	4.558	3.999			
Coefficient of performance (COP)	kW/kW	2.69	4.87	6.95	8.89	2.54	2.69			

Electric power consumptions	Unit	Value
Thermostat-off mode [P _{TO}]	kW	0.026
Standby mode [P _{SB}]	kW	0.015
Crankcase heater [P _{CK}]	kW	0.038
Off mode [P _{OFF}]	kW	0.015

Project No: 64.181.24.00497.01

Rev.: 00 Date: 2024-06-17 Page: 6 of 19







3.Calculation/conclusion for SCOP:											
Tdesignh(°C):	-10		Tbiv(°C):	-7							
Pdesignh(kW):	12.169		TOL(°C):	-10							
Test result A, B, C, D, E, F conditions:											
Condition	Part load	Measured capacity	Measured COP	Cdh	CR	COP at part load					
E	12.169	11.560	2.54	0.90	1.00	2.54					
F	10.765	10.765	2.69	0.90	1.00	2.69					
А	10.765	10.765	2.69	0.90	1.00	2.69					
В	6.552	6.594	4.87	0.90	0.99	4.87					
С	4.212	7.070	6.95	0.90	0.60	6.51					
D	1.872	8.021	8.89	0.90	0.23	6.69					
CR: part load di	CR: part load divided by capacity;										

Conclusions:	Unit	Value
SCOPon:	kWh/kWh	4.81
SCOP:	kWh/kWh	4.80
Q _H :	kWh/year	25140
Q _{HE} :	kWh/year	5240
$\eta_{s,h}$	%	188.9
Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 2)		A+++

Project No: 64.181.24.00497.01

Rev.: 00 Date: 2024-06-17 Page: 7 of 19





Table 2.	Heating mod	le (Medium t	empe	rature app	plication):			ı	P
Model	MONOBLOC	K TF18 R290) CT 2	20V						
Product type	Air to Water	Heating season	7	Average		Warn	ner		Colder	
1. Test condit	tions:								-	
Condition	F	Part Load Ra	atio		hea	Outdo at exch		er		r heat anger
Condition	Form	nula		verage imates		dry (wangeratu	,			let water ures (°C)
Α	(-7-16)/(Tde	(-7-16)/(Tdesignh-16)		88		-7(-8	3)		a /	52
В	(+2-16)/ (Td	lesignh-16)		54		2(1))		a /	42
С	(+7-16)/(Td	esignh-16)		35		7(6))		a /	36
D	(+12-16)/(To	designh-16)		15		12(11	1)		a /	30
E	(TOL	-16)/ (Tdesiզ	gnh-16	5)		TOL	-		a/:	55.3
F	(Tbival	signh-	16)	Tbiv			a / 52			
G	(-15-16)/(Tdesignh-16)			N/A		-15			N/A	
2.Tested data				00000	A 7 / A / C	no I	A40	W/00	I A/ 40\/	I A / 3\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \
General test conditions/ Part-Load	Unit	A(-7)/W52 (88%)		2/W42 54%)	A7/W3 (35%			W30 5%)	A(-10)/ W55.3 (100%)	A(-7)/W52 (88%)
		А		В	С		[)	Е	F
Data collection period	hh: min:sec	3:00:00	1	:10:00	1:10:0	00	1:10	0:00	3:00:00	3:00:00
The heat pump defrosts		Yes		No	No		Ν	lo	Yes	Yes
Electrical Prop	erties					-			-	
Voltage	V	229.3	2	230.4	230.7	7	23	0.8	229.3	229.3
Current input of the unit	А	21.62		7.48	5.84		5.	21	21.97	21.62
Power input of the unit	kW	4.920		1.683	1.299	9	1.1	50	4.997	4.920
Compressor frequency	Hz	85		35	30		3	0	85	85

Doc No.: ITC-TTW0902.02E - Rev.15

Project No: 64.181.24.00497.01

Rev.: 00 Date: 2024-06-17 Page: 8 of 19





Test condition	Test conditions User Side										
Water flow	m³/h	1.25	1.25	1.25	1.25	1.25	1.25				
Inlet Water temperature	°C	44.42	37.51	33.25	28.69	47.30	44.42				
Outlet Water temperature	°C	51.69*	41.94	37.81	33.93	54.36*	51.69*				
Test conditions Source Side											
Barometric pressure	kPa	99.85	99.85	99.85	99.80	99.75	99.85				
Air inlet temperature, DB	°C	-7.01	2.00	7.00	12.00	-9.97	-7.01				
Air inlet temperature, WB	°C	-8.11	1.03	6.01	10.98	-10.96	-8.11				
Summary of th	e results										
Total heating capacity	kW	10.430	6.366	6.583	7.570	10.125	10.430				
Effective power input	kW	4.917	1.679	1.295	1.146	4.993	4.917				
Coefficient of performance (COP)	kW/kW	2.12	3.79	5.08	6.60	2.03	2.12				
Remark: * In pa	Remark: * In part condition, outlet temperature data is recorded by the full average complete cycle's data.										

	po	, - a 15p a.ta	 	

Electric power consumptions	Unit	Value
Thermostat-off mode [P _{TO}]	kW	0.026
Standby mode [P _{SB}]	kW	0.015
Crankcase heater [P _{CK}]	kW	0.038
Off mode [P _{OFF}]	kW	0.015



3.Calculation/conclusion for SCOP:										
Tdesignh(°C):	-10		Tbiv(°C):	-7						
Pdesignh(kW):	11.791		TOL(°C):	-10						
Test result A, B, C, D, E, F conditions:										
Condition	Part load	Measured capacity	Measured COP	Cdh	CR	COP at part load				
Е	11.791	10.125	2.03	0.90	1.00	2.03				
F	10.430	10.430	2.12	0.90	1.00	2.12				
А	10.430	10.430	2.12	0.90	1.00	2.12				
В	6.349	6.366	3.79	0.90	1.00	3.79				
С	4.081	6.583	5.08	0.90	0.62	4.79				
D	1.814 7.570		6.60	0.90	0.24	5.01				
CR: part load di	vided by capac	city;		•						

Conclusions:	Unit	Value
SCOPon:	kWh/kWh	3.69
SCOP:	kWh/kWh	3.68
Q _H :	kWh/year	24360
Q _{HE} :	kWh/year	6612
$\eta_{s,h}$	%	144.4
Seasonal space heating energy efficiency classes: (According (EU) No 811/2013 Table 1)		A++

Doc No.: ITC-TTW0902.02E - Rev.15

Project No: 64.181.24.00497.01

Rev.: 00 Date: 2024-06-17 Page: 10 of 19





Table 3a.	Sound power level	Р			
Model	MONOBLOCK TF18	3 R290 CT 220V			
	Product type :			Air to Water	
	Outdoor heat excha	nger, Air temperature I	DB/WB (°C):	7.0 / 6.0	
	Indoor heat exchang	ger, Water inlet/outlet t	emperature (°C):	30.0 / 35.0	
	Voltage (V):			230	
	Frequency (Hz):	50			
	Working condition class :			Class A	
	Acoustical environment :			Hemi-anechoic room	
	Windshield type :			Sponge	
	Measured position amount :			14	
Mea	sured quantity	L _{WA,indoors} (dB(A))	L _{WA,outdoors} (dB(A))	Remark	
Sound pressure level $\bar{L}_{p(ST)}^{****}$			48		
Measurement distance d *			1.0m		
Sound pow	ver level L _{wA} ****		63		
Setting of c	ontrols; according to user manual.				

Setting of controls: according to user manual.

Duct connection:-

Rounding to: *) 1 decimal places; **) 2 decimal places; ***) 3 decimal places; ****) nearest integer

Doc No.: ITC-TTW0902.02E - Rev.15

Project No: 64.181.24.00497.01

Rev.: 00

Date: 2024-06-17 Page: 11 of 19







Table 3b.	Sound power level	Р		
Model	MONOBLOCK TF18			
	Product type :			Air to Water
	Outdoor heat exchar	nger, Air temperature I	DB/WB (°C):	7.0 / 6.0
	Indoor heat exchang	er, Water inlet/outlet t	emperature (°C):	47.0 / 55.0
	Voltage (V):			230
	Frequency (Hz):			50
	Working condition class :			Class A
	Acoustical environment : Windshield type :			Hemi-anechoic room
				Sponge
	Measured position amount :			14
Meas	sured quantity	L _{WA,indoors} (dB(A))	L _{WA,outdoors} (dB(A))	Remark
Sound pressure level $\bar{L}_{p(ST)}^{****}$			48	
Measurement distance d *			1.0m	
Sound pow	er level L _{wA} ****		63	

Setting of controls: according to user manual.

Duct connection:--

Rounding to: *) 1 decimal places; **) 2 decimal places; ***) 3 decimal places; ****) nearest integer

Doc No.: ITC-TTW0902.02E - Rev.15

Project No: 64.181.24.00497.01

Rev.: 00

Date: 2024-06-17 Page: 12 of 19



TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China



Table 4.	Clause 4 of EN 14511-4:2022	Р
Model:	MONOBLOCK TF18 R290 CT 220V	
TEST 1	STARTING TEST (§4.2.1.2 Table 3)	

Requirement: The "lower" starting operating conditions declared by the manufacturer for the heating modei.e. Tair= -25.00 °C, T in water = 8.45 °C, Flow rate 1.12 m³/h have been set and obtained. At those conditions, the machine was switched on.

Observation/ Evaluation: It started without any problem and worked for 30 minutes without showing any warning or alarm. During the test the machine operated in auto mode. No damage was recorded on the machine during and after the test.

Test Response: Pass

TEST 2 OPERATING TEST (§4.2.1.2 Table 3)

Requirement: From the machine "lower" starting conditions - i.e. - the machine was brought to the lower operating conditions declared by the manufacturer for the heating mode- i.e. Tair= -25.00 °C, T in water = 50.88°C, Flow rate 1.12 m³/h. Once these conditions were obtained, the machine was let operate for over 1 hour in auto mode.

Observation/ Evaluation: During the test, no waring or alarm were showed. No damage was recorded on the machine during and after the test.

Test Response: Pass

TEST 3 SHUTTING OFF WATER FLOW (§ 4.5)

Requirement: The water flow rate was shuted off through manual and automatic valves of the test rig. The machine switched off and only the flow switch Protection appeared on the user interface of indoor unit.

Observation/ Evaluation: Perform error reset operation, once the water flow rate was restored, the machine restarted automatically and worked for 30 minutes normally. No damage was recorded on the machine during and after the test.

Test Response: Pass

TEST 4 SHUTTING OFF AIR FLOW (§ 4.5)

Requirement: The air flow rate was shutted off through a plastic sheet and a panel. The machine never turned off. It continued to operate with continuous frosting and defrosting cycles. After more than half an hour, the air flow rate was restored and the machine started to operate normally.

Observation/ Evaluation: During the test, no waring or alarm were showed. No damage was recorded on the machine during and after the test.

Test Response: Pass

COMPLETE POWER SUPPLY FAILURE (§ 4.6) TEST 5

Requirement: The power supply was cut off for about 5 seconds.

Observation/ Evaluation: The unit restarted automatically within about 3 minutes after the power supply was reactivated.

Test Response: Pass

Project No: 64.181.24.00497.01

Rev.: 00 Date: 2024-06-17 Page: 13 of 19



www.tuvsud.com



Appendix II Marking plate

Nameplate

Model: MONOBLOCK TF18 R290 CT 220V

ThermoFLUX DC Inverter toplotne pumpa zrak-voda

DC Inverter Air Source Heat Pumps			
Model	MONOBLOCK TF18 R290 CT 220V		
Napajanje	220-240V~/50Hz		
Power Supply	220-240V~/30HZ		
Kapacitet grijanja min./max.	6,90 / 15,00 kW		
Heating Capacity min./max.	0,90 / 13,00 kW		
Potrošnja el. energije - grijanje	1,33 / 3,92 kWh		
Heating Input Power min./max.	1,55 / 5,52 KWII		
COP grijanje min./max.	3,83 / 5,17		
Heating COP min./max.	3,03 / 3,17		
Kapacitet hlađenja min./max.	5,7 / 12,4 kW		
Cooling Capacity min./max.	5,7 7 12,4 800		
Potrošnja el. energije - hlađenje	1,60 / 5,17 kWh		
Cooling Input Power min./max.	1,00 / 3,17 KVVII		
Prosječna potrošnja/Jačina struje	7,83 kWh / 37,5 A		
Rated. Input Power/Current	7,03 KWII 7 37,3 A		
Max. temperatura polaza vode	75°C		
Max. Water Outlet Temperature	750		
Max. protok cirk. pumpe	6,2 m ³ /h		
Max. Water Pump Flow	0,2 111 /11		
Max. dobava cirk. pumpe	10,5 m		
Max. Water Pump Head	10,5 111		
Nazivni protok	3,1 m ³ /h		
Rated Water Flow	3,1 111 /11		
Rashladno sredstvo / težina			
Refrigerant/Weight	R290 / 1,8 kg		
Niski i visoki radni pritisak freona	0.05 / 2.2 MP-		
Low/High side operation pressure	0,85 / 3,2 MPa		
Max. dozvoljeni pritisak freona	2.2 MD-		
Maximum allowable pressure	3,2 MPa		
Max. pritisak vode	1.0.140-		
Max Water Pressure	1,0 MPa		
Otpornost na udarce	T		
Shock Proof Grade	I		
Klasa vodootpornosti	IPX4		
WaterProof Level	IPX4		
Pad pritiska na vodenoj strani	25 kPa		
Water Pressure Drop	23 KFa		
Hidraulički priključak	1"		
Water Pipe Connection	<u>'</u>		
Netto težina	147 kg		
Net Weight	147 kg		
Datum:/Serijski broj:	Pogledati bar code		
Date: /NO.:	See bar code		
Ekvivalentna težina punjenja sustava CO2: 0,0054 tona			

Ekvivalentna težina punjenja sustava CO2: 0,0054 tona

System CO2 aquivalent charge weight: 0,0054 ton

*Radni uslovi grijanja:

*Heating working condition:

Temperatura suhog termometra 7°C, temperatura mokrog 6°C Dry bulb temperature 7°C, Wet bulb temperature 6°C Temperatura ulazne vode 30°C, temperatura izlazne vode 35°C Inlet water temperature 30°C, Outlet water temperature 35°C

> ThermoFLUX d.o.o. Bage br. 3, 70101 Jajce Bosna i Hercegovina www.thermoflux.ba







Project No: 64.181.24.00497.01

Rev.: 00 Date: 2024-06-17 Page: 14 of 19

www.tuvsud.com



Appendix III photo documentation

Details of:	Overall view
View:	
☐ General	The state of the s
☐ Front	
□ Rear	
□ Right	Grand Control of the
□ Left	The state of the s
□ Тор	
□ Bottom	Gran and Gra
	Agencies of the second

Details of:	Compressor	
View: ☐ General	Panasonic H650D7VZAAC6	
☐ Front	COMPRESSOR TÜV DC MOTOR 520V	
□ Rear	SERIAL NO. V657	
□ Right	F9999998 7975741 Panasonic Corporation R290	
□ Left	Panasonic Wanhoo And Line Manager Made in China	
□ Тор	District, Guang Thou City One, Zhong Cun,	
☐ Bottom	WARNING/DANGER 注意 (维修, 检查时必须遵守) Danger of Electric Shock 有触电的危险 Disconnect power before work. 操作前演切断全部电源。 Danger of Electric Shock 有触电的危险 Disconnect power before work. 操作前演切断全部电源。 Danger of Electric Shock 有触电的危险 和在空間主机上接入地线。 Danger of Electric Shock 有触电的危险 和在空間主机上接入地线。 Danger of Electric Shock 有触电的危险 Danger of Electric Shock 有触电的反应 Danger of Electric Shock 有触电的 Danger of Electric Shock 和 Danger of	

Doc No.: ITC-TTW0902.02E - Rev.15

Project No: 64.181.24.00497.01

Rev.: 00

Date: 2024-06-17 Page: 15 of 19





Appendix III photo documentation

Fan Motor	
WOLONG 空间用天身直流电动机 ZWB278D04A(1821300) DC310V 102W 8P 920r/min MOLONG ELECTRIC GROUP CO.,LTD. WOLONG ELECTRIC GROUP CO.,LTD.	

Details of:	Main Control Board
View: General Front Rear Right Top Bottom	

Doc No.: ITC-TTW0902.02E - Rev.15

Project No: 64.181.24.00497.01

Rev.: 00

Date: 2024-06-17 Page: 16 of 19





Appendix III photo documentation

Details of:	Water Pump	
View:		
☐ General	GRUNDFOS X UPM10L	
☐ Front	25-105 130	
□ Rear	EEL < 0.20 - Part 3 PLant ≤ 82WV 230V ≈ 50/60HzHz IPX4D TF110 GFBSA . Min20°C P/N:93032863 PC:2335CHU	
□ Right	S/N: S/N: Made in Denmark Groundar Michiga M/S (MC-0850 Bigner Inglier) Boomer's Brownish	
□ Left	C€	
□ Тор		
□ Bottom		

Doc No.: ITC-TTW0902.02E - Rev.15

Project No: 64.181.24.00497.01

Rev.: 00

Date: 2024-06-17 Page: 17 of 19





Appendix IV Construction data form

Part		Technical data
1. Compressor		1 00111110411 04444
·	Manufacture:	Panasonic Wanbao Appliances Compressor
		(Guangzhou) Co., Ltd.
	Type:	H650D7VZAAC6
	Rated capacity:	3640W
	Serial-number:	F999998
	Specification:	DC520V; R290
2. Condenser		
	Manufacture:	Jiangsu Yuanzhuo Equipment Manfactur Co.,Ltd
	Type:	ZL62FA-40AD-CG
	Heat exchanger:	Plate heat exchanger
	Dimension(mm):	526(L)mmX119(H)mmX91(D)mm
3. Evaporator		
	Manufacture:	Guangzhou Aotai Refrigeration Equipment Co.,Ltd.
	Type:	06KH-CP-01
	Heat exchanger:	Finned-coil heat exchanger
	Dimension(mm):	660.4(L)mmX1300(H)mmX343.3(D)mm
4. Fan motor		
	Manufacture:	Wolong Electric Group Co., Ltd
	Type:	ZWB278D04A
	Fan type:	3 blade
	Specification:	DC310V; 102W
5. Main control board		
	Manufacture:	CAREL
	Type:	UP3F00200T3S04
	Specification:	220-240V~; 50Hz
6. Water pump		
	Manufacture:	GRUNDFOS
	Type:	UPM10L 25-105 130
	Specification:	230V~; 50/60Hz
*(Alternative)		
•	Manufacture:	Shinhoo
	Type:	GPA25-11H
	Specification:	230V~; 50Hz

Remark: * means the test results were not performed on the alternative components.

Doc No.: ITC-TTW0902.02E - Rev.15

Project No: 64.181.24.00497.01

Date: 2024-06-17 Page: 18 of 19



TÜV SÜD Certification and Testing (China) Co., Ltd. Guangzhou Branch

5F&8F East, Communication Building, No.163 Pingyun Road, Huangpu Ave. West, Guangzhou 510656, China Tel: +86 20 38320668



Appendix V Equipment List

No.	Туре	Manufacture	Model	Equipment ID	Calibration Due Date
1	Heat pump energy efficiency testing system	PINXIN	10HP	2017J00001	2023-11-24
2	Electromagnetic flowmeter	KROHNE	OPTIFLUX4100C	H17221264	2023-12-21
3	Anechoic rooms (hemi-anechoic rooms)	Guangzhou Kinte	-	NC-036-2	2024-10-07
4	AC source Supply	YANGHONG	YF-3600	VGDS-0637	2024-11-07
5	6 channel data logger	_	PXI-1033	VGDY-0257	2024-05-20
6	PULSE system	B & K	3660C	VGDY-0184	2024-04-12
7	Calibrator	B & K	4231	HJ-000095	2024-06-30
8	Long steel tape	_	5m	HJ-000150	2024-01-01
9	Temperature measurement system	_	_	NC-036-1	2024-06-07
10	Atmospheric pressure meter	_	_	HJ-000165	2023-11-22
11	Constant temperature water system	B & K	_	VGDS-0448	2024-04-18
12	Windscreen	B & K	WS002-5	_	

-- End of Report --

Doc No.: ITC-TTW0902.02E - Rev.15

Project No: 64.181.24.00497.01

Rev.: 00 Date: 2024-06-17 Page: 19 of 19



